



# **SECTION**

## **NOTES:**

1. CONCRETE WETWELL SECTIONS SHALL BE CONNECTED BY STEEL STRAPS. CONTRACTOR SHALL SUBMIT METHOD TO S.L.C.U. OR ENGINEER OF RECORD FOR APPROVAL ALONG WITH SHOP DRAWINGS.
2. SEE TYPICAL LIFT STATION DETAILS FOR ADDITIONAL DESIGN AND CONSTRUCTION STANDARDS.

LBFH INC. - CADD FILE NAME: L/CAD-DETAILS/SLC/SLC-WW25.DWG



## **ST. LUCIE COUNTY WATER & WASTEWATER CONSTRUCTION STANDARDS**

## **LIFT STATION TREMIE POUR DETAIL**

DRAWING NUMBER: **WW-25**